मोलाना आज़ाद नेशनल उर्दू यूनिवर्सिटी

مولانا آزاد نيشنل اُر دويو نيورشي MAULANA AZAD NATIONAL URDU UNIVERSITY

(A Central University established by an Act of Parliament in 1998)

PURCHASE & STORES SECTION

No. MANUU/Purchase/F.08/2013-14/Vol.I/234

13th June 2016

To,

Sub: MANUU - Purchase – To supply and installation 11 KVA UPS for D.D.E – Limited Tender Enquiry – Reg.

Sir,

The University intends to supply and install 11 KVA UPS at D.D.E as per the specification mentioned below from the original manufacturer / supplier / Govt. organization only. You are requested to submit quotations in sealed envelope as per Annexure-I on a printed letter head of the firm consisting the details as per attached proforma, on or before 27th June 2016 by 02.00 p.m. and the tender will be opened on the same day at 3:00 p.m. in the presence of prospective bidders.

Specification of 11KVA UPS:

Sl.	Particulars	Qty. reqd.
1.	11 KVA UPS: Online ups with isolated transformer with PWM technology floor	01
	mounted type suitable for three /single phase AC input voltage 160V to 260V, 50 +/-1.5	
	Hz or higher and single phase AC output voltage 230+/-1% V, 50 +/- 0.5 Hz, housed in	
	rugged enclosure made of M.S. sheet 1.2 mm (minimum) thick aesthetically finished	
	duly pretreated and powder coated along with SMF 42 AH (three years warranty) with	
	stand	

Terms & Conditions:

- 1. Price's are to be quoted both in figures and in words. In case of a discrepancy, that quoted in words/ lowest amount will be taken as valid.
- 2. The bidder should be a reputed firm.
- 3. Incomplete Bids in any respect are liable to be rejected.
- 4. The bid must mention the specifications as per the Annexure -1 and to submit the sample (if any) as required by the University.
- 5. The quantity included in the bid can be increased or decreased at the discretion of the Competent Authority, Maulana Azad National Urdu University Hyderabad.
- 6. The supply of said items has to be made within a period of two weeks from the date specific time, 0.5% cost of the whole supply for every week as late supply will be deducted from the bill to the maximum of 10% after which the order will remain cancelled. Incase, if the firm supplies inferior quality, the University may at its decision reject the entire material and impose penalty.

مولانا آزاد نیشنل اُر دویو نیورسی LIDDI LINIVEDSITY

MAULANA AZAD NATIONAL URDU UNIVERSITY

(A Central University established by an Act of Parliament in 1998)

PURCHASE & STORES SECTION

- 7. Item offered in the tender enquiry may be re-ordered at the same rate, terms & conditions within a period of twelve months/one year.
- 8. The amount quoted should include all the charges including taxes, transportation, etc.
- 9. All pages of the tender document are to be signed and stamped by the tendering firm and to be attached along with the bids.
- 10. Conditional bids are not accepted.
- 11. The University reserves all the rights to place the order items wise with the firm quoted L-1 rates.
- 12. The L-1 firms should submit 10% EMD in the form of D.D drawn from any nationalized bank in favour of MANUU payable at Hyderabad which will be returned after the execution of Purchase Order.
- 13. For any query/clarification, you may contact Purchase & Stores Section.
- 14. The University reserves all the rights to reject or accept any tender without assigning any reason or cancel or withdraw the tender notice.
- 15. In case of any dispute, Hyderabad will be the Jurisdiction. The Registrar, Maulana Azad National Urdu University, Hyderabad shall decide the issue and his decision will be final and shall be binding on the both parties.

Assistant Registrar (Purchase & Stores)



MAULANA AZAD NATIONAL URDÜ UNIVERSITY

(A Central University established by an Act of Parliament in 1998)



PURCHASE & STORES SECTION

Annexure-I

11 KVA UPS

Particulars	Make &	Qty.	Unit	Total
	Model	reqd.	Price	Amount
11 KVA UPS: Online ups with isolated transformer with PWM technology floor mounted type suitable for three /single phase AC input voltage 160V to 260V, 50 +/-1.5 Hz or higher and single phase AC output voltage 230+/-1%V, 50 +/- 0.5 Hz, housed in rugged enclosure made of M.S. sheet 1.2 mm (minimum) thick aesthetically finished duly pretreated and powder coated along with SME 42 AH (three years warranty)		01		(inclusive of all)
	11 KVA UPS: Online ups with isolated transformer with PWM technology floor mounted type suitable for three /single phase AC input voltage 160V to 260V, 50 +/-1.5 Hz or higher and single phase AC output voltage 230+/-1%V, 50 +/- 0.5 Hz, housed in rugged enclosure made of M.S. sheet 1.2 mm (minimum)	Model 11 KVA UPS: Online ups with isolated transformer with PWM technology floor mounted type suitable for three /single phase AC input voltage 160V to 260V, 50 +/-1.5 Hz or higher and single phase AC output voltage 230+/-1%V, 50 +/- 0.5 Hz, housed in rugged enclosure made of M.S. sheet 1.2 mm (minimum) thick aesthetically finished duly pretreated and powder coated along with SMF 42 AH (three years warranty)	Model 11 KVA UPS: Online ups with isolated transformer with PWM technology floor mounted type suitable for three /single phase AC input voltage 160V to 260V, 50 +/-1.5 Hz or higher and single phase AC output voltage 230+/-1%V, 50 +/- 0.5 Hz, housed in rugged enclosure made of M.S. sheet 1.2 mm (minimum) thick aesthetically finished duly pretreated and powder coated along with SMF 42 AH (three years warranty)	Model reqd. Price 11 KVA UPS: Online ups with isolated transformer with PWM technology floor mounted type suitable for three /single phase AC input voltage 160V to 260V, 50 +/-1.5 Hz or higher and single phase AC output voltage 230+/-1%V, 50 +/- 0.5 Hz, housed in rugged enclosure made of M.S. sheet 1.2 mm (minimum) thick aesthetically finished duly pretreated and powder coated along with SMF 42 AH (three years warranty)

Place: Signature of the authorized Date: 2016 representative of the firm with stamp